

**CONFORMITY TO THE NORM EN 303-5:2012**

ACTECO srl has tested on September 10 2012 the heating boiler for solid fuels

**COMPACT 35 2012 - RED**

manufactured by MCZ GROUP S.p.A., via La Croce, 8 - I - 33074 Vigonovo di Fontanafredda (PN) according to the efficiency prescriptions of European standard EN 303-5:2012, with the following results:

Water heat output	Efficiency	CO		NOx		OGC		Dust	
		mg/MJ	mg/Nm <sup>3</sup> (10% O <sub>2</sub> )	mg/MJ	mg/Nm <sup>3</sup> (10% O <sub>2</sub> )	mg/MJ	mg/Nm <sup>3</sup> (10% O <sub>2</sub> )	mg/MJ	mg/Nm <sup>3</sup> (10% O <sub>2</sub> )
kW	(%)								
32,0	92,8	34,0	60,0	95,2	196	0,8	2,0	11,1	22,6

The boiler complies with

**CLASS 5**

of the European standard EN 303-5:2012.

The results are listed in the test report Nr. 0542-12NB dated September 19 2012 included in the Technical File of the product.

Cordenons, 19.09.2012

Head of Test Laboratory  
dr. Mario Marcuzzi

