

CONFORMITY TO THE NORM EN 303-5:1999

ACTECO srl has tested on April 10 2012 the heating boiler for solid fuels

COMPACT 24 2012 - RED

manufactured by MCZ GROUP S.p.A., via La Croce, 8 - I - 33074 Vigonovo di Fontanafredda (PN) according to the efficiency prescriptions of the norm EN 303-5:1999, with the following results:

Water heat output	Efficiency	CO		NOx		OGC		Dust	
		mg/MJ	mg/Nm ³ (10% O ₂)	mg/MJ	mg/Nm ³ (10% O ₂)	mg/MJ	mg/Nm ³ (10% O ₂)	mg/MJ	mg/Nm ³ (10% O ₂)
kW	(%)								
22,1	90,2	83	171	88	181,4	0,1	0,1	12,0	24,5

The boiler complies with

CLASS 3

of clause 4.2.6 of the European standard EN 303-5:1999.

The boiler complies with

CLASS 5

of the European standard prEN 303-5:2012.

The results are listed in the test report Nr. 0305-12NB dated Aprile 23 2012 included in the Technical File of the product.

Cordenons, 23.04.2012

Head of Test Laboratory
dr. Mario Marcuzzi

