

CONFORMITY TO THE NORM EN 303-5:2012

ACTECO srl has tested on April, 15 2015 the heating boilers for solid fuels

COMPACT 14 - 2015

manufactured by MCZ S.p.a., Via La Croce, 8 - I – 33074 Vigonovo di Fontanafedda (PN) according to the efficiency prescriptions of the norm EN 303-5:2012, with the following results:

		Nominal	Minimum
Water heat output	kW	12,3	3,3
Efficiency	%	90,6	91,5
CO	mg/MJ	42	130
CO (10% O ₂)	mg/Nm ³	86	269
CO (13% O ₂)	mg/Nm ³	62	196
NO _x as NO ₂	mg/MJ	100	84
NO _x as NO ₂ (10% O ₂)	mg/Nm ³	207	173
NO _x as NO ₂ (13% O ₂)	mg/Nm ³	150	126
OGC	mg/MJ	<1	2
OGC (10% O ₂)	mg/Nm ³	<1	5
OGC (13% O ₂)	mg/Nm ³	<1	3
Dust	mg/MJ	10,6	35,7
Dust (10% O ₂)	mg/Nm ³	21,8	73,5
Dust (13% O ₂)	mg/Nm ³	15,8	53,5

The results of the tests relate only to the tested appliance.
This test report shall not be reproduced except in full, without written approval of the laboratory.
The appliance was returned to the manufacturer after the end of tests.

All data is stored for 10 years

Pag. 1 / 2

The boiler **COMPACT 14 - 2015** of **MCZ GROUP SPA** complies with:

CLASS 5

of clause 4.4 of the European standard EN 303-5:2012.

The results are listed in the test report Nr. 1880-CPR-017-15 dated May, 21 2015 included in the Technical File of the product.

Cordenons, 21.05.2015

Head of Test Laboratory
dr. Mario Marcuzzi